

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Flow Switch**

with type designation(s)

BFS-10/30/40-N/NE/L-G1/4"...G11/2"-SS/MS-NO/WE-ST

Issued to

Barksdale GmbH
REICHELSEIM, WETTERAU, Germany

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

Temperature	B
Humidity	B
Vibration	A
EMC	B
Enclosure	B (IP65)

Issued at **Hamburg** on **2018-08-23**for **DNV GL**This Certificate is valid until **2023-08-22**.DNV GL local station: **Augsburg**Approval Engineer: **Jens Dietrich**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

BFS-10/30/40-N/NE/L-G1/4"...G1 1/2"-SS/MS-NO/WE-ST:

For monitoring volume flow of liquids

Measuring range: 0,005...0,06 to 35...250 l/min

Accuracy: +/- 10% FS

Housing material: brass or stainless steel

Operating pressure [bar]: PN 100 bar (brass-housing)

PN up to 350 bar (stainless-steel-housing)

Electrical connection: plug acc. to DIN EN 175301-803-C (Ex DIN 43650 C),
-803-A (Ex DIN 43650 A)

Contact rating: 1/4"	200V / 1A / 20VA (NO/SPDT)
1/2"	250V / 1,5A / 50VA (SPDT)
	230V / 3A / 60VA (NO)
≥1"	250V / 3A / 100VA (NO)
	250V / 1,5A / 50VA (NO/SPDT)

Degree of protection: IP65.

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Type Approval documentation

Test report: BFSV UB 8155 / 12 dated 6th December 2012

Data sheets: 923-1837, Rev.C; 923-1855, Rev.D; 923-1857, Rev.C.

Assembly drawings: 922-1228A, Rev. C; 922-1230A, Rev. B; 922-1284, Rev. A.

Periodical assessment report, DNV GL Augsburg, dated 2018-07-31.

Tests carried out

Applicable tests according to class guideline DNV GL CG-0339, November 2016.

Marking of product

Manufacturer, type designation, serial number.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate



Job Id: **262.1-028812-1**
Certificate No: **TAA0000204**

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of this certificate.

END OF CERTIFICATE