VOXZ.S1215 Switches, Pressure

Page Bottom

Switches, Pressure

See General Information for Switches, Pressure

BARKSDALE INC S1215

3211 FRUITLAND AVE LOS ANGELES, CA 90058 USA

Pressure-operated switches: Sprinkler system alarm and supervisory service, Cat. Nos. E1H-B15, -B15-U, -B15-P6-U, -B15-P6-PLS-U, -M15-U, -M15-P6-U, -M15-P6-U, -M15-P6-U, -M20-P6-U, -M20-P6-U, -M20-P6-U, -M20-P6-PLS-U, rated 1.0 to 20 psi; E1H-B90-Q18, -B90-U, -B90-P6-U, -B90-P6-PLS-U, -M90-P6-U, -M90-P6-PLS-U, rated 3.0 to 90 psi; E1H-B250-U, -B250-P6-U, -B250-P6-PLS-U, -M250-P6-U, -M250

Pressure switches, Cat. Nos. D1H , D1T , D2T followed by A, B, C, E, F or H, followed by 2, 3, 18, 80 or 150, may be followed by SS, followed by - UL (i.e. DIH-A3SS-UL).

Diaphragm and Rating:

Suffix	Adjustable Range psi
2	0.018 to 1.7
2SS	0.018 to 1.7
3	0.03 to 3.0
3SS	0.03 to 3.0
80	0.50 to 80.0
80SS	0.50 to 80.0
150	1.50 to 150.0
150SS	1.50 to 150.0
18	0.40 to 18.0
18SS	0.40 to 18.0

Electrical ratings: Catalogs employing suffix B, 6.5 amps, 12-14 v, dc; 1.5 amps, 24-28 v, dc; 0.33 amp, 125 v, dc; 0.25 amp, 250 v, dc; 10 amps, 125-250 v, ac. 1/8 hp, 125 v, ac; 1/4 hp, 250 v, ac. Pilot duty 125 va, 125-250 v, ac. Catalogs employing suffix M, rated 3.3 amps, 12-14 v, dc; 1.0 amp, 125-28 v, dc; 125-28 v, dc; 125-28 v, ac; 125-28 v, a

Pressure-operated switches: Sprinkler system alarm and supervisory service, Cat. Nos. E1H-G15-RD-U, -G15-P6-RD-U, -G15-P6-PLS-RD-U, rated 0.5 to 15 psi. E1H-G20-RD-U, -G20-P6-RD-U, -G20-P6-PLS-RD-U, rated 1.0 to 20 psi. E1H-G90-RD-U, -G90-Q25, -G90-P6-RD-U, -G90-P6-PLS-RD-U, rated 3.0 to 90 psi. E1H-G250-RD-U, -G250-P6-RD-U, -G250-P6-PLS-RD-U, rated 10.0 to 250 psi. Electrical ratings: 15 amp at 125-250 v, ac; 6.5 amp

at 12 v, dc; 1.5 amp at 24 v, dc; 0.33 amp at 125 v, dc.

Last Updated on 1994-07-09

Questions? Notice of Disclaimer Page Top

Copyright © 2009 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright \hat{A} © 2009 Underwriters Laboratories Inc. \hat{A} ®"